
KRO-4000

Power Supply & Readout Unit

Instruction Manual



www.kns-int.com

Table of Contents

| | |
|--|----|
| 1. General Information | 2 |
| 1-1. Introduction | 2 |
| Feature | 2 |
| Specifications | 2 |
| Dimension | 3 |
| Ordering Information | 4 |
| 2. Installation | 5 |
| 2-1. Environmental Requirements | 5 |
| 2-2. Interconnection | 5 |
| MFC Pin Assignment | 5 |
| I/O Pin Assignment | 6 |
| RS-232C Pin Assignment | 6 |
| 3. Operation | 7 |
| 3-1. Overview | 7 |
| Front Panel Description | 7 |
| Rear Panel Description | 7 |
| Flow On / Off | 7 |
| Safty On / Off | 7 |
| 3-2. System Flow Chart | 8 |
| 3-3. Setup Menu | 9 |
| Function (Setup Menu Display) | 9 |
| Control Mode (Local & Remote) Select | 9 |
| Full Scale Select | 10 |
| Address Select | 10 |
| Unit Select | 11 |
| Decimal Point Select | 11 |
| Flow Error Rate Select | 12 |
| Auto Zero Adjust | 12 |
| Relay High & Low | 13 |
| Memory Clear | 14 |
| 3-4. Communication & Protocol | 15 |

1. General Information

1-1. Introduction

Feature

Model KRO-4000(Power supply & readout unit) MFC(Mass Flow Controller)
 (Set-point Value) (Flow Value) Display MFC가

±15 VDC (50W-4Channel) , Channel
 MFC가

A/D, D/A Converter (Set-point Value) (Flow Value)
 4Digit - 7Segment Display (Calibration) 가
 Digital (Repeatability)
 (Reproduction)

Switch (Rear Panel) Safty 가
 Micro Processor Program Option Processor
 가

Specifications

- Display Resolution : 4 Digit - 7 Segment, Adjustable Decimal Location
- Display Repeatability : ± 0.1% of Full Scale
- Input to The KRO-4000 Controller : 0 to 5 Volts For Full Scale of MFC
- Output Signal : 0 to 5 Volts into > 10 K
- Output Power : ± 15 VDC (0.5 Amp)
- Units of Display : SCCM, SLM, %
- Decimal Point : User Selectable Range "0.0.0.0"
- Remote Control : I/O - 9 Pin D-Sub (Male)
 - Set-point Control : 0 to 5 Volts for Full Scale of Analog Signal
 - Flow On/Off Control : Digital Input - TTL
 - Flow On/Off Reserved : Digital Output - TTL (Open Collector)
 - Flow Out Signal : 0 to 5 Volts for Full Scale of MFC
 - Trip Point : 1 Relay Per Flow Channel (Standard)
- RS-232C Input / Ouput (Optional) : 9600 Baud, 8-N-1, Available through The Accessory Connector
 : User Selectable Address, RS-485C (Optional)
- Accumulation Control (Optional)
- Ratio Control (Optional)
- Time Control (Optional) : Timer Function
- Operating Voltage : 220 VAC (50/60Hz)

Caution

220VAC 50/60Hz

가 Install Manual Option Ground

()KNS International

Dimension




Figure 1 : Model KRO-4000 1CH




Figure 1 : Model KRO-4000 1/2 Half Rack (1~2CH)

<Panel Cutting Size>




Figure 2 : Model KRO-4000 Half Rack (1~4CH)

(: mm)

Dimension





Figure 3 : Model KRO-4000 Full Rack (1~8CH)

(: mm)

Ordering Information



Note : Purge 가

Note : Other Function

가 Idea가

2. Installation


2-1. Environmental Requirements

KRO-4000 Controller

- Normal Operating Temperature Range : 0 to 50
- Warm-up Time : < 5 min
- Operating Humidity : 0 to 95 %
- : 220 VAC (60 Hz), Option
- System Ground가
-


2-2. Interconnection

MFC Pin Assignment




Model KRO-4000 MFC Connector - 9 Pin Female D-Sub Connector

| Name | Pin No | FUNCTION |
|------------------|--------|--------------------------------|
| GND | 1 | Ground |
| GND | 2 | Ground |
| -15 vdc | 3 | MFC -15VDC |
| GND | 4 | Ground |
| +15 vdc | 5 | MFC +15VDC (+24 VDC : Option) |
| Set-point Signal | 6 | Output 0-5 VDC (4-20mA:Option) |
| Flow Signal | 7 | Input 0-5 VDC (4-20mA:Option) |
| GND | 8 | Ground |
| GND | 9 | Chassis Ground |

I/O Pin Assignment

Model KRO-4000 I/O Connector - 9 Pin Male D-Sub Connector

| Name | Pin No | FUNCTION |
|--------------|--------|---|
| TTL output | 1 | MFC Switch (on "0.6 vdc", off "0vdc") |
| TTL Input | 2 | MFC Switch (on "0 vdc - GND", off "Open") |
| GND | 3 | Ground |
| Relay N.O | 4 | Relay N.O |
| Relay common | 5 | Relay common |
| GND | 6 | Ground |
| Flow Signal | 7 | Read 0-5 vdc |
| Flow control | 8 | Input 0-5 vdc |
| Relay N.C | 9 | Relay N.C |

RS-232C Pin Assignment


Model RO-4000 RS-232C Connector - 9 Pin Male D-Sub Connector

| Name | Pin No | FUNCTION |
|------|--------|---------------|
| N/C | 1 | N/C |
| T/X | 2 | Transmit data |
| R/X | 3 | Receive data |
| N/C | 4 | N/C |
| GND | 5 | Ground |
| N/C | 6 | N/C |
| N/C | 7 | N/C |
| N/C | 8 | N/C |
| N/C | 9 | N/C |


3. Operation

3-1. Overview


Front Panel Description



Rear Panel Description




Flow On / Off




- Main Switch On Display Main Mode
- Note : Version (4001,4002....)
- Main Mode "ENT" Key On (One Touch) Display Set-point Value가
- " ", " " Key 가
- "ENT" Key On (One Touch)
- "Flow On/Off" Key On (One Touch) Control MFC 가 MFC
- Control MFC Flow Reading Flow Value Displa
- . ---> " Status 1. "G-FLOW"
- Note : Flow On Set-point Value 가

Safety On / Off




- Main Mode " " Key 3 Safety Mode
- " ", " " Key On/Off
- "ENT" Key On (One Touch) Main Mode
- On : Switch
- Off : Switch

3-2. System Flow Chart




3-3. Setup Menu

Function (Setup Menu Display)

| | |
|-----------------|--|
| Front Display |  <p><Setup Menu></p> <p>"●" Status 2. "Y-FUN"</p> |
| Function | Main Mode Setup Mode |
| Hardware Action | Main Mode " " Key 3 Setup Mode "ENT" Key On () -> Menu (Control Mode) |
| Note | |

Control Mode (Local & Remote) Selection

| | |
|-----------------|---|
| Front Display |  <p><Local></p> <p><Remote></p> <p>"●" Status 2. "Y-FUN"</p> <p>"●" Status 2. "Y-FUN" "●" Status 1. "Y-RMT"</p> |
| Function | Local : Front & (RS-232C & RS-485) Control Remote : I/O - "RMT & COM" (9 pin) Control -. S.V (Set-point) Reading -> I/O 8pin -. Flow On/Off -> I/O 2pin -. Flow On/Off -> I/O 1pin |
| Hardware Action | Function (Setup Menu) "ENT" Key On(One Touch) Remote Control In/Out Signal -. I/O "RMT & COM" 8pin : 0 to 5 vdc Input Signal -. I/O "RMT & COM" 2pin : Switch (On "GND", Off " Open") Input -. I/O "RMT & COM" 1pin : Switch (On "0.6 VDC", Off "0 VDC") Output (Open Collect) "ENT" Key On (One Touch) -> Menu (Full Scale Select) |
| Note | Set-point Reading Set-point Value Display Switch On "●" Status 1. "G-FLOW" Flow On Control Switch Out "0.6VDC" " Flow On/Off " Key On (One Touch) Main Mode |


Full Scale Select

| | |
|-----------------|---|
| Front Display | <p>" " Status 2. "Y-FUN" (Min. 0020 ~ Max. 5000)</p> |
| Function | <p>Channel MFC Full Scale MFC Maximum Flow</p> <p>- Note : MFC Gas Flow MFC Gas Conversion Factor Full Scale</p> |
| Hardware Action | <p>Control Mode "ENT" Key On (One Touch) " ", " " Key Full Scale "ENT" Key On (One Touch) -> Menu (Address Select)</p> |
| Note | <p>" Flow On/Off " Key On (One Touch) Main Mode</p> |


Address Select

| | |
|-----------------|---|
| Front Display | <p>" " Status 2. "Y-FUN"</p> |
| Function | <p>Serial(RS-232C or RS-485) Cntrl Channel Protocol Rack Channel 1 Address Channel</p> <p>- Note : Channel</p> |
| Hardware Action | <p>Full Scale Mode "ENT" Key On (One Touch) " ", " " Key Address "ENT" Key On (One Touch) -> Menu (Address Select)</p> |
| Note | <p>" Flow on/off " Key On (One Touch) Main Mode</p> |


Unit Select

| | |
|------------------------|---|
| <p>Front Display</p> |  <p><SCCM> "•" LED-</p> <p><SLM> "•" LED-</p> <p><%> "•" LED-</p> <p>"•" Status 2. "Y-FUN" SCCM, "SLM", "PER"</p> |
| <p>Function</p> | <p>MFC SCCM : Standard Cubic Centimeters per Minute = mL/Min SLM : Standard Liters per Minute = L/Min % : Percentage</p> |
| <p>Hardware Action</p> | <p>Address Mode "ENT" Key On (One Touch) " ", " " Key "ENT" Key On (One Touch) -> Menu (Decimal Point)</p> |
| <p>Note</p> | <p>" Flow on/off " Key On (One Touch) Main Mode</p> |


Decimal Point Select

| | |
|------------------------|---|
| <p>Front Display</p> |  <p>"•" Status 2. "Y-FUN"</p> |
| <p>Function</p> | |
| <p>Hardware Action</p> | <p>Unit Mode "ENT" Key On (One Touch) " ", " " Key "ENT" Key On (One Touch) -> Menu (Flow Error Rate Select)</p> |
| <p>Note</p> | <p>" Flow On/Off " Key On (One Touch) Main Mode</p> |

Flow Error Rate Select

| | | | | | | | | | | | | | | | | | | | | | | | | | |
|-----------------------|---|------------|----------------------------|---|---|-----------------------|--|--|--|------------------|-----|---|----------------------------|------------------|-----|---|------------------|-----|---|------------------|-----|---|------------------|-----|---|
| Front Display |  <p>● Status 2. "Y-FUN"</p> <p>Error -> "● Status 1. "R-FALT"</p> | | | | | | | | | | | | | | | | | | | | | | | | |
| Function | <table border="0"> <tr> <td>Flow Value</td> <td>Set-point Value</td> <td>가</td> <td>.</td> </tr> <tr> <td>"0" -> Error Rate Off</td> <td></td> <td></td> <td></td> </tr> <tr> <td>"1" -> P.V , S.V</td> <td>±1%</td> <td>.</td> <td rowspan="5">} "● Status 1. "R-FALT"</td> </tr> <tr> <td>"2" -> P.V , S.V</td> <td>±2%</td> <td>.</td> </tr> <tr> <td>"3" -> P.V , S.V</td> <td>±3%</td> <td>.</td> </tr> <tr> <td>"4" -> P.V , S.V</td> <td>±4%</td> <td>.</td> </tr> <tr> <td>"5" -> P.V , S.V</td> <td>±5%</td> <td>.</td> </tr> </table> <p>- Note : Error Rate Flow On -> 20 Flow Value 가 Set-point Value</p> | Flow Value | Set-point Value | 가 | . | "0" -> Error Rate Off | | | | "1" -> P.V , S.V | ±1% | . | } "● Status 1. "R-FALT" | "2" -> P.V , S.V | ±2% | . | "3" -> P.V , S.V | ±3% | . | "4" -> P.V , S.V | ±4% | . | "5" -> P.V , S.V | ±5% | . |
| Flow Value | Set-point Value | 가 | . | | | | | | | | | | | | | | | | | | | | | | |
| "0" -> Error Rate Off | | | | | | | | | | | | | | | | | | | | | | | | | |
| "1" -> P.V , S.V | ±1% | . | } "● Status 1. "R-FALT" | | | | | | | | | | | | | | | | | | | | | | |
| "2" -> P.V , S.V | ±2% | . | | | | | | | | | | | | | | | | | | | | | | | |
| "3" -> P.V , S.V | ±3% | . | | | | | | | | | | | | | | | | | | | | | | | |
| "4" -> P.V , S.V | ±4% | . | | | | | | | | | | | | | | | | | | | | | | | |
| "5" -> P.V , S.V | ±5% | . | | | | | | | | | | | | | | | | | | | | | | | |
| Hardware Action | <p>Decimal Point Mode "ENT" Key On (One Touch) " , " " " Key Error Rate "ENT" Key On (One Touch) -> Menu (Address Select)</p> | | | | | | | | | | | | | | | | | | | | | | | | |
| Note | <p>" Flow On/Off " Key On (One Touch) Main Mode</p> | | | | | | | | | | | | | | | | | | | | | | | | |


Auto Zero Adjust

| | |
|-----------------|--|
| Front Display |  <p>* Note : Flow Zero -></p> <p>Real Flow Rate -></p> <p>● Status 2. "Y-FUN"</p> |
| Function | <p>MFC Auto Zeroing</p> <p>- Note : Warm-up</p> |
| Hardware Action | <p>Flow Error Mode "ENT" Key On (One Touch) " , " " " Key On/Off "ENT" Key On (One Touch) -> Menu (Relay High)</p> |
| Note | <p>" Flow On/Off " Key On (One Touch) Main Mode</p> |

Relay High & Low

| | |
|------------------------|---|
| <p>Front Display</p> | <p><Relay High></p> <p>" ENT" Key On</p> <p><Relay Low></p> <p>" Status 2. "Y-FUN"</p> |
| <p>Function</p> | <p>Flow Value Relay</p> <p>I/O - "RMT & COM" (4,5,9 pin) Relay Control</p> <p>Reading P.V (Flow Value)</p> <p>Relay Hi-Low -> N/O</p> <p>Relay Hi-Low -> N/C</p> <p>- Note : Full Scale Relay</p> |
| <p>Hardware Action</p> | <p>Zero Adjust Mode "ENT" Key On (One Touch)</p> <p>" ", " " Key</p> <p>ex) - Relay Hi -> "80.0"</p> <p> "ENT" Key -> .</p> <p> Relay Low -> "40.0"</p> <p>- P.V (Flow Value)-> "50.0"</p> <p> Relay N/O -> I/O 4, 5pin</p> <p>- P.V (Flow Value)-> "30.0"</p> <p> Relay N.C -> I/O 5, 9pin</p> <p>"ENT" Key On (One Touch) -> Menu (Memory Clear)</p> |
| <p>Note</p> | <p>" Flow On/Off " Key On (One Touch) Main Mode</p> |

Memory Clear

| | |
|-----------------|--|
| Front Display |  <p>"Y" Status 2. "Y-FUN"</p> |
| Function | Memory |
| Hardware Action | Relay High & Low Mode "ENT" Key On (One Touch) " ", " " Key On/Off "ENT" Key On (One Touch) -> Menu (Control Mode) |
| Note | " Flow On/Off " Key On (One Touch) Main Mode Memory clear -. Full Scale -> "4.000" -. S.V (Set-point) -> "0.000" -. Safety -> "off" -. Unit -> "SCCM" -. Control Mode -> "Local" -. Address -> "1" -. Decimal Point -> "0.000" -. Error Rate -> "0" -. Zero Adjust -> "off" -. Relay Hi -> "4.000" -. Relay Low -> "0.000" -. Memory Clear -> "off" |

3-4. Communication & Protocol

Communication

- Baud Rate : 9600 bps
- Data Bit : 8 Bit
- Parity Bit : None *Note : Data . -> 0.3 - 0.5 sec
- Stop Bit : 1 Stop Bit
- Command and Data : Hexa-code
- Data Form : (Address), (Command), (High Data), (Low Data)
- Receive Check Sum : (High Data) + (Low Data)
 ex) Oct (1750) -> Hex (03E8)
 Check Sum -> 03 + E8 = EB

Caution

1) , KRO-4000 (Address) .
 ex) 4 Channel 1 ->2 ->3 ->4 .

2) (Address) -> 0x = Address-1
 ex) 2 Channel Data . -> 0x = 01

3) Data . . Data Check Sum . (Delay Time : 0.2-0.3 sec)

Protocol

| | | Send Message | | | | Receive Message | | | | | | | | | | | | | | | | | |
|---|-------------|--|-----------------|-----------------|----------------|------------------------|--------------|-----------------|-------------|------------|-----------------|----------------|----------------|---------------|---------------|-----------------|-----------|-----------|--|--|--|--|--|
| Flag | I.N | Send Buffer | | | | Receive Buffer | | | | | | | | | | | | | | | | | |
| Flow Test On | e1 | 0x | e1 | Set Flow High | Set Flow Low | • | • | • | • | | | | | | | | | | | | | | |
| Flow Test Off | e0 | 0x | e0 | Set Flow High | Set Flow Low | • | • | • | • | | | | | | | | | | | | | | |
| Full Scale | e2 | 0x | e2 | Full Scale High | Full Scale Low | • | • | • | • | | | | | | | | | | | | | | |
| Status | e3 | 0x | e3 | Statu High | Statu Low | • | • | • | • | | | | | | | | | | | | | | |
| Relay High | e4 | 0x | e4 | Relay High High | Relay High Low | • | • | • | • | | | | | | | | | | | | | | |
| Relay Low | e5 | 0x | e5 | Relay Low High | Relay Low Low | • | • | • | • | | | | | | | | | | | | | | |
| Flow Value Return Command | f0 | 0x | f0 | • | • | • | • | • | • | | | | | | | | | | | | | | |
| Total Information Return Command | f6 | <table border="1"> <tr> <td rowspan="2">0x</td> <td rowspan="2">e0 or e1</td> <td>Flow High</td> <td>Flow Low</td> <td>Set Flow High</td> <td>Set Flow Low</td> <td>Full Scale High</td> <td rowspan="2">Check Sum</td> </tr> <tr> <td colspan="6">Check Sum</td> </tr> </table> | | | | | | | | 0x | e0 or e1 | Flow High | Flow Low | Set Flow High | Set Flow Low | Full Scale High | Check Sum | Check Sum | | | | | |
| | | 0x | e0 or e1 | Flow High | Flow Low | Set Flow High | Set Flow Low | Full Scale High | Check Sum | | | | | | | | | | | | | | |
| | | | | Check Sum | | | | | | | | | | | | | | | | | | | |
| <table border="1"> <tr> <td>Full Scale Low</td> <td>Status High</td> <td>Status Low</td> <td>Relay High High</td> <td>Relay High Low</td> <td>Relay Low High</td> <td rowspan="2">Check Sum</td> </tr> <tr> <td colspan="6">Relay Low Low</td> </tr> </table> | | | | | | | | Full Scale Low | Status High | Status Low | Relay High High | Relay High Low | Relay Low High | Check Sum | Relay Low Low | | | | | | | | |
| Full Scale Low | Status High | Status Low | Relay High High | Relay High Low | Relay Low High | Check Sum | | | | | | | | | | | | | | | | | |
| Relay Low Low | | | | | | | | | | | | | | | | | | | | | | | |
| <table border="1"> <tr> <td>Relay Low Low</td> <td>Check Sum</td> </tr> </table> | | | | | | | | Relay Low Low | Check Sum | | | | | | | | | | | | | | |
| Relay Low Low | Check Sum | | | | | | | | | | | | | | | | | | | | | | |

| | | Send Message | | | | | | | | Receive Message | | | | | |
|--------------------------------------|------|--------------|-----|---------|---------|---------|---------|--------|-------|-----------------|--------|--|-------|-------|-------|
| Flag | I.N | Send Buffer | | | | | | | | Receive Buffer | | | | | |
| * Status | | | | | | | | | | | | | | | |
| NULL | SCCM | SLM | PER | POINT-3 | POINT-2 | POINT-1 | POINT-0 | REMOTE | ADJON | RCONON | ACONON | | ERATE | ERATE | ERATE |
| * Note : Ox = (Address -1) | | | | | | | | | | | | | | | |



www.kns-int.com

가 178-270 202
TEL : 032-572-2846~7, FAX : 032-572-2848